

Validator Provided

Audit Information:

PWS ID: CA1010004

Audit Period: July 1, 2019 – June 30, 2020

Sufficient Supporting Documents Provided: Yes

Key Audit Metrics:

Apparent Loss: 127.186 AF

Non-revenue water as percent of cost of operating system: 4.1%

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

If not, rejected recommendations are included here.

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Certified Validation Report Template

Part B: Provided by Utility

Water Supplier Name: City of Coalinga

Water Supplier ID Number: CA1010004

Water Audit Period: July 1, 2019 – June 30, 2020

Water Audit & Water Loss Improvement Steps:

- Testing of largest customer water meters
- Calibration of treated water meters at water plant
- More frequent monitoring of treated water output from water plant
- Potential reinstallation of Westlands Water Meter
- Implement customer meter replacement program
- Convert to AMR/AMI system

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)


Executive Position

Signature

Date

Sean Brewer

Assistant City Manager



1/14/2012

Utility Provided